Bently Nevada Service Manual

107770-04-01

1. Description

Part Number: 107770-04-01

3. Product Information

Part Number: 107770-04-01

Model: Velocity Transducer Housing – CENELEC approved

Manufacturer: Bently Nevada

Condition: New & Original in Factory Packing

Factory Warranty: 12 Months

Ordering Information

Model: 107770 - Velocity Transducer Housing – CENELEC approved

Mounting Thread Option:04 =1/2-14 BSP

Cable Exit Fitting Option:01=1/2-14 NPT plug

This version is a combination of the 330500

Velomitor Sensor and a 21128 Housing preinstalled at the factory. It is also rated for

CENELEC Zone 1, Group IIC hazardous area

applications.

RoHS

RoHS Directive 2011/65/EU

Hazardous Area Conditions of

Safe Use

ATEX/IECEx

Zone 0/1:

Equipment must be connected to equipment,

which meets the abovelisted entity

parameters.

The cables type A or B (in compliance with EN

60079-25) must respect the cable parameters

listed with the entity parameters.

Zone 2:

The supply electrical parameters shall not

exceed the values mentioned in the tables

above.