Bently Nevada 330105&330106 Series Service Manual

330105-02-12-30-02-05

1. Description

Manufacturer : Bently Nevada

3. Product Information

Manufacturer : Bently Nevada

Product No. : 330105-02-12-30-02-05

Product type : Reverse Mount Probes

Made in U.S.A

Model: 330105-02-12 - 3300 XL 8 mm Reverse Mount Probes

Total Length Option: -30 3.0 meters

Connector Option: -02 Miniature ClickLoc coaxial

connector

Agency Approval Option: -05 CSA, ATEX, IECEx Approvals

Dimension : 20.4 cm x 22.2 cm x 3.7 cm

Nominal Probe DC Resistance

Resistance (RPROBE) from Center Conductor

to Outer Conductor

Probe

Length (m)

RPROBE(Ω)

3.0 8.17 ± 0.50

Probe

Case

Thread

Maximum Length of Thread

Engagement

3/8-24 0.563 in

Probe 323 g/m (11.4 oz)

Probe Temperature Range

Operating and Storage Temperature

Standard

Probe

-52°C to +177°C (-62°F to

+350°F)

Extended

Temperature

Range Probe

-52°C to +218°C (-62°F to

+425°F) for the probe tip; -

51°C to +260°C (-60°F to

+500°F) for the probe cable

and connector.

Exposing the probe to temperatures

below –34˚C (-30˚F) may cause

premature failure of the pressure

seal.

Probe Pressure

3300 XL 8 mm probes are designed to seal

differential pressure between the probe tip

and case. The probe sealing material consists

of a Viton® O ring. Probes are not pressure

tested prior to shipment.

Probe Relative Humidity

Less than a 3% change in Average Scale

Factor (ASF) when tested in 93% humidity in

accordance with IEC standard 68 2 3 for up to

56 days.

Hazardous Area Approvals

ia

When installed

with

intrinsically

safe zener

barriers per
drawing 141092
or when
installed with
galvanic
isolators.
Class I, Zone 0: AEx/Ex ia IIC T5...T1 Ga;
Class 1, Groups A, B. C, and D,
Class II, Groups E, F, and G,
Class III;
nA, ec
When installed
with nonincendive
circuit
connected per
drawing
140979.
Class I, Zone 2: AEx/Ex nA IIC T5...T1 Gc;
Class 1, Division 2, Groups A, B, C, D;
Class 1, Zone 2: AEx/Ex ec IIC T5...T1 Gc;
Class I, Division 2, Groups A, B, C, and
D;
Temperature Schedule
Temperature
Classification
Ambient Temperature
(Probe Only)
For EPL Ga and Gc
T1 -55°C to +232°C
T2 -55°C to +177°C
T3 -55°C to +120°C
T4 -55°C to +80°C
T5 -55°C to +40°C
For EPL Dc
T280°C @ Ta -55°C to +232°C
T225°C @ Ta -55°C to +177°C
T170°C @ Ta -55C to +120°C
T130°C @ Ta -55°C to +80°C
T105°C @ Ta -55°C to +100°C
T90°C @ Ta -55°C to +40°C